

§ 965.800

standards prescribed in this subpart, such units, child care facilities, exterior or interior common areas are not required to be re-tested or re-treated.

(Information collection requirements contained in this section were approved by the Office of Management and Budget under control number 2577-0090)

[53 FR 20803, June 6, 1988, as amended at 56 FR 15175, Apr. 15, 1991]

§ 965.710 Compliance with state and local laws.

(a) *PHA responsibilities.* Nothing in this subpart H is intended to relieve a PHA of any responsibility for compliance with state or local laws, ordinances, codes or regulations governing lead-based paint testing or hazard abatement. The PHA shall maintain records evidencing compliance with applicable state or local requirements, and shall report information concerning such compliance, in accordance with such requirements as shall be prescribed by HUD.

(b) *HUD responsibility.* If HUD determines that a state or local law, ordinance, code or regulation provides for lead-based paint testing or hazard abatement in a manner which provides a comparable level of protection from the hazards of lead-based paint poisoning to that provided by the requirements of this subpart and that adherence to the requirements of this subpart would be duplicative or otherwise cause inefficiencies, HUD may modify or waive the requirements of this subpart in such manner as may be appropriate to promote efficiency while ensuring such comparable level of protection.

(Approved by the Office of Management and Budget under control number 2577-0090)

[51 FR 27789, Aug. 1, 1986. Redesignated at 53 FR 20803, June 6, 1988]

§ 965.711 Monitoring and enforcement.

PHA compliance with the requirements of this subpart will be included in the scope of HUD monitoring of PHA operations. Non-compliance with any requirement of this subpart may subject a PHA to sanctions provided under the Annual Contribution Contract or to enforcement by other means authorized by law.

[51 FR 27789, Aug. 1, 1986. Redesignated at 53 FR 20803, June 6, 1988]

Subpart I—Fire Safety

SOURCE: 57 FR 33853, July 30, 1992, unless otherwise noted.

24 CFR Ch. IX (4-1-00 Edition)

§ 965.800 Applicability.

This subpart applies to all PHA-owned or -leased housing housing, including Mutual Help and Turnkey III.

§ 965.805 Smoke detectors.

(a) *Performance requirement.* (1) After October 30, 1992, each unit covered by this subpart must be equipped with at least one battery-operated or hard-wired smoke detector, or such greater number as may be required by state or local codes, in working condition, on each level of the unit. In units occupied by hearing-impaired residents, smoke detectors must be hard-wired.

(2) After October 30, 1992, the public areas of all housing covered by this subpart must be equipped with a sufficient number, but not less than one for each area, of battery-operated or hard-wired smoke detectors to serve as adequate warning of fire. Public areas include, but are not limited to, laundry rooms, community rooms, day care centers, hallways, stairwells, and other common areas.

(b) *Acceptability criteria.* (1) The smoke detector for each individual unit must be located, to the extent practicable, in a hallway adjacent to the bedroom or bedrooms. In units occupied by hearing-impaired residents, hard-wired smoke detectors must be connected to an alarm system designed for hearing-impaired persons and installed in the bedroom or bedrooms occupied by the hearing-impaired residents. Individual units that are jointly occupied by both hearing and hearing-impaired residents must be equipped with both audible and visual types of alarm devices.

(2) If needed, battery-operated smoke detectors, except in units occupied by hearing-impaired residents, may be installed as a temporary measure where no detectors are present in a unit. Temporary battery-operated smoke detectors must be replaced with hard-wired electric smoke detectors in the normal course of a PHA's planned CIAP or CGP program to meet the required HUD Modernization Standards or state or local codes, whichever standard is stricter. Smoke detectors for units occupied by hearing-impaired